



EQUALIZING FLOW IN COIL & BY-PASS IN 3-WAY VALVE INSTALLATIONS

1. ADJUST VALVE ON BALVALVE-VENTURI TO READING ON TAG WITH FULL FLOW THROUGH COIL.
2. ADJUST BALANCE VALVE IN BY-PASS LINE WITH FULL FLOW THROUGH BY-PASS, SO THAT METER READING EQUALS TAG READING.
3. PRESSURE DROP OF BY-PASS LINE WILL THEN EQUAL PRESSURE DROP OF COIL.

